

Closeup photo of the disconnected building sewer lateral, an overall photo of work and property, and site address will need to be emailed to permits.inspection@westvalleysan.org to initiate a District permit inspection. The District does **not** require the property owner or property owner representative to be present at the time of inspection. Once the District assesses your disconnection, the point of contact will be notified of the results of the inspection.

The local jurisdiction demolition signoff sheet can be posted at the property or brought to the District office, by making an appointment, for District signoff.

Following are the requirements that must be met for disconnection of a building sewer lateral.

Requirement #1: Building connection to sewer lateral verified by property owner or property owner representative

It is the responsibility of the property owner or property owner representative to verify the exact number and location of sewer laterals connected to the building being demolished; and that all sewer lateral connections are disconnected per District requirements.

Requirement #2: Sewer lateral disconnected at property line and capped

Building sewer lateral shall be disconnected at the property line and capped as shown in Figure 1 below.

Requirement #3: Location marker at sewer lateral disconnection installed for future connection reference

Location marker shall be installed in accordance with Figure 1 below prior to District inspection.




FIGURE 1. Cutting, plugging, and marking for temporary disconnection of building sewer lateral.